
Quarter Mile Lane School

Water Cooler, Hall Rt by Rm A-111

First Draw (ppb)**51.6****30-sec Flush (ppb)**

n/a

2017 – zero failures

New Warehouse

NONE

First Draw (ppb)**30-sec Flush (ppb)****2017 – zero failures**

Admin Building

Sink, Asst Super Office

First Draw (ppb)**29.1****30-sec Flush (ppb)**

1.67

2017 – zero failures

Excel BldgWater Cooler, 3rd Floor Hall Left**First Draw (ppb)****34.9****30-sec Flush (ppb)**

n/a

Water Cooler, 3rd Floor Hall Right**25.8**

n/a

2017 – zero failures

Bridgeton HS

Water Cooler, Hall by Rm J10

First Draw (ppb)**17.3****30-sec Flush (ppb)**

n/a

Bubbler – Room J1

23.0

1.69 (Will take out of svcs)

Bubbler – Room J2

80.1

12.5 (Will take out of svcs)

Bubbler – Hall Right by Rm F5

70.6**55.7**

Bubbler – H-Hall Left by Gym

28.0**20.3****2017 – zero failures**

West Ave School

Bubbler – Room A1

First Draw (ppb)**23.0****30-sec Flush (ppb)**

6.65

Bubbler – Room A3

58.9

8.39

Bubbler – Room A4

35.2

6.16

Bubbler – Room A5

178

7.45

Bubbler – Room A7 **2017 –****47.6**

13.7

zero failures
